

# Air Source Heat Pumps: Measured Performance & Best Practices

NESEA BE19 – 03/14/2019

Andy Shapiro  
Bruce Harley  
Marc Rosenbaum

# Case Study: Energy Futures Group Building

March 2019

## Overall Goal

*A net zero, energy efficient, green  
building*

*David Pill, Architect*

*Chuck Reiss, Builder*

*Andy Shapiro, Energy Design*


# Before and After -- ~2,400 sq.ft.



# EFG's Energy Goals

- All-electric net zero model project
  - Tight: 1.0 ACH50
  - R-5 windows
  - R-20 foundation
  - R-40 walls
  - R-60 ceilings
  - Cold climate heat pumps
  - Energy recovery ventilation, ~70% effectiveness, EC motors
  - On-site renewables
  - Green, healthy and re-used materials
- Participate in Efficiency Vermont's Commercial New Construction Program and achieve Net Zero standard

# Design Heat Loads – Btu/hr – Original Calculations




Two Heat Pumps: Office Total: 17,500 Btu/hr  
Rental Total 16,400 Btu/hr

# Transfer Fans

*(Panasonic 110-150 cfm)*

1" door undercut all offices



So did we  
make Net  
Zero???

After the first three months of heating the building, the heat pumps used as much energy as the model showed they would use in a full heating season!

What's Up???

# HP Sizing

## Conventional “UA - delta T” calculation

| Conventional Heating Systems Sizing     |           |          |                          |
|---|-----------|----------|--------------------------|
|   | Area      | U-Value  | UA                       |
| Roof                                    | 1,317     | 0.017    | 22                       |
| Wall                                    | 2,313     | 0.025    | 58                       |
| Window                                  | 292       | 0.2      | 58                       |
| Doors                                   | 103       | 0.33     | 34                       |
|   | Perimeter | Btu/ft-F |                          |
| Slab/Basement                           | 171       | 0.25     | 43                       |
|   | Volume    | ACH      |                          |
| Infiltration**                          | 17,125    | 0.39     | 120                      |
|   |           |          |                          |
| TOTAL UA -- Btu/hr-F                    |           |          | <b>335</b>               |
| ** Includes ventilation and natural ACH |           |          |                          |
| Heating Design Outdoor Temp             |           |          | -20                      |
| Inside Design Temp                      |           |          | 68                       |
| Design Heat Load, Btu/hr                |           |          | 29,500                   |
| Add for "Pick-Up"                       |           |          | 15% <b>33,900</b>        |
| Split into two outdoor units            |           |          | Design Heat Load, Btu/hr |
| (EFG offices and rental)                |           | Offices  | <b>17,500</b>            |
|   |           | Rental   | <b>16,400</b>            |



# HP Sizing

Conventional  
"UA - delta T"  
calculation

| Conventional Heating Systems Sizing |           |          |            |
|-------------------------------------|-----------|----------|------------|
|                                     | Area      | U-Value  | UA         |
| Roof                                | 1,317     | 0.017    | 22         |
| Wall                                | 2,313     | 0.025    | 58         |
| Window                              | 292       | 0.2      | 58         |
| Doors                               | 103       | 0.33     | 34         |
|                                     | Perimeter | Btu/ft-F |            |
| Slab/Basement                       | 171       | 0.25     | 43         |
|                                     | Volume    | ACH      |            |
| Infiltration**                      | 17,125    | 0.39     | 120        |
| TOTAL UA -- Btu/hr-F                |           |          | <b>335</b> |

\*\* Includes ventilation and natural ACH

|                             |     |
|-----------------------------|-----|
| Heating Design Outdoor Temp | -20 |
| Inside Design Temp          | 68  |

|                          |        |
|--------------------------|--------|
| Design Heat Load, Btu/hr | 29,500 |
|--------------------------|--------|

|                   |     |               |
|-------------------|-----|---------------|
| Add for "Pick-Up" | 15% | <b>33,900</b> |
|-------------------|-----|---------------|

|   |         |                          |
|---|---------|--------------------------|
| Split into two outdoor units (EFG offices and rental) |         | Design Heat Load, Btu/hr |
|   | Offices | <b>17,500</b>            |
|   | Rental  | <b>16,400</b>            |

| design      |                                       |
|-------------|---------------------------------------|
| <b>0.12</b> | <b>Natural ACH</b>                    |
| 290         | peak cfm from ventilation             |
| 100%        | duty cycle                            |
| 290         | avg cfm from ventilation              |
| 0.74        | HRV apparent effectiveness            |
| 75          | average effective cfm                 |
| <b>0.26</b> | <b>avg. effective ventilation ACH</b> |
| <b>0.39</b> | <b>Total ACH for model</b>            |

# Picking the Heat Pump

| Area / No. Heads | Btu/hr<br>Required |
|------------------|--------------------|
| Rental / 3       | 16,400             |
| Offices / 2      | 17,500             |

# Picking the Heat Pump

| Area / No. Heads | Btu/hr<br>Required | Model        |
|------------------|--------------------|--------------|
| Rental / 3       | 16,400             | MXZ-3C24NAHZ |
| Offices / 2      | 17,500             | MXZ-2C20NAHZ |

# Picking the Heat Pump

| Area / No. Heads | Btu/hr<br>Required | Model                 | Btu/hr<br>at -13F | % Oversize |
|------------------|--------------------|-----------------------|-------------------|------------|
| Rental / 3       | 16,400             | MXZ- <b>3</b> C24NAHZ | 20,500            | 25%        |
| Offices / 2      | 17,500             | MXZ- <b>2</b> C20NAHZ | 22,500            | 29%        |

# HP Sizing

## Dialing in the Peak Heat Load

ACH based on actual air leakage

| Improved Heating Systems Sizing for ASHP              |           |             |                                 |
|---|-----------|-------------|---------------------------------|
|   | Area      | U-Value     | UA                              |
| Roof  | 1,317     | 0.017       | 22                              |
| Wall  | 2,313     | 0.025       | 58                              |
| Window  | 292       | 0.2         | 58                              |
| Doors   | 103       | 0.33        | 34                              |
|   | Perimeter | Btu/ft-F    |                                 |
| Slab/Basement   | 171       | 0.25        | 43                              |
|   | Volume    | <b>ACH</b>  |                                 |
| Infiltration**  | 17,125    | <b>0.18</b> | 55                              |
| TOTAL UA -- Btu/hr-F                                  |           |             | <b>271</b>                      |
| Heating Design Outdoor Temp                           |           |             | -20                             |
| Inside Design Temp                                    |           |             | 68                              |
| Design Heat Load, Btu/hr                              |           |             | 24,000                          |
| <b>Add for "Pick-Up"</b>                              |           | <b>15%</b>  | <b>28,000</b>                   |
| Split into two outdoor units (EFG offices and rental) |           |             | <b>Design Heat Load, Btu/hr</b> |
|   | Offices   |             | <b>14,400</b>                   |
|   | Rental    |             | <b>13,600</b>                   |

**0.03 cfm50/sq.ft. shell instead of 0.1**

# HP Sizing

Dialing in the Peak Heat Load

Lose the "Pick-Up"

| Improved Heating Systems Sizing for ASHP              |           |          |                          |
|---|-----------|----------|--------------------------|
|   | Area      | U-Value  | UA                       |
| Roof  | 1,317     | 0.017    | 22                       |
| Wall  | 2,313     | 0.025    | 58                       |
| Window  | 292       | 0.2      | 58                       |
| Doors   | 103       | 0.33     | 34                       |
|   | Perimeter | Btu/ft-F |                          |
| Slab/Basement   | 171       | 0.25     | 43                       |
|   | Volume    | ACH      |                          |
| Infiltration**  | 17,125    | 0.18     | 55                       |
| TOTAL UA -- Btu/hr-F                                  |           |          | 271                      |
| Heating Design Outdoor Temp                           |           |          | -20                      |
| Inside Design Temp                                    |           |          | 68                       |
| Design Heat Load, Btu/hr                              |           |          | 24,000                   |
| Add for "Pick-Up"                                     |           | 0%       | 24,000                   |
| Split into two outdoor units (EFG offices and rental) |           |          | Design Heat Load, Btu/hr |
|   |           | Offices  | 12,400                   |
|   |           | Rental   | 11,600                   |

# HP Sizing

Dialing in  
the Peak  
Heat Load

Use current  
ASHRAE 99%  
Heating  
Design Temp

| Improved Heating Systems Sizing for ASHP              |           |             |                          |
|---|-----------|-------------|--------------------------|
|   | Area      | U-Value     | UA                       |
| Roof  | 1,317     | 0.017       | 22                       |
| Wall  | 2,313     | 0.025       | 58                       |
| Window  | 292       | 0.2         | 58                       |
| Doors   | 103       | 0.33        | 34                       |
|   | Perimeter | Btu/ft-F    |                          |
| Slab/Basement   | 171       | 0.25        | 43                       |
|   | Volume    | <b>ACH</b>  |                          |
| Infiltration**  | 17,125    | <b>0.18</b> | 55                       |
| TOTAL UA -- Btu/hr-F                                  |           |             | <b>271</b>               |
| Heating Design Outdoor Temp                           |           |             | <b>-1.8</b>              |
| Inside Design Temp                                    |           |             | 68                       |
| <b>Design Heat Load, Btu/hr</b>                       |           |             | <b>19,000</b>            |
| <b>Add for "Pick-Up"</b>                              |           |             | <b>0% 19,000</b>         |
| Split into two outdoor units (EFG offices and rental) |           |             | Design Heat Load, Btu/hr |
|   |           | Offices     | 9,800                    |
|   |           | Rental      | 9,200                    |

|                        |                    |                 |                 |
|------------------------|--------------------|-----------------|-----------------|
| Outside design temp, F | -20                | -7              | <b>-1.8</b>     |
| Source of design temp  | Common VT practice | ASHRAE 1977 99% | ASHRAE 2017 99% |

Summary:

Dialing in  
the Peak  
Heat Load

| Design Heat Load, Btu/hr                           |             |                      |              |                          |
|--|-------------|----------------------|--------------|--------------------------|
|  | Initial     | As-Built Air Leakage | Lose Pick-Up | Warmer -1.8F Design Temp |
| Total load   | 33,900      | 28,000               | 24,000       | 19,000                   |
| Load/HP Capacity                                   | <b>133%</b> | <b>161%</b>          | <b>188%</b>  | <b>237%</b>              |
| Capacity: NEEP -13F Btu/hr total for two 24K units |             |                      |              | 45,000                   |

*Two 24k units were installed, not on 20 and one 24....*



What's the  
REAL COP of  
the Heat  
Pumps?

What's the  
REAL COP of  
the Heat  
Pumps???

If we know the heat load of the building and we know how much energy the heat pump takes we can calculate COP:

$$\text{COP} = \frac{\text{heat load energy}}{\text{heat pump energy}}$$

Calculating  
COP

If it takes 1 kW of resistance heat to  
keep the building 30 degrees  
warmer than outside

and

It takes 0.5 kW to do that using the  
heat pumps

then

$\text{COP} = 1.0 \text{ kW heat} / 0.5 \text{ kW electricity}$

$\text{COP} = 2.0$

How to find  
the REAL  
COP???




“Co-Heating” Test:

Heat the building with electric resistance heat for some days and heat it with the heat pumps other days, alternating.

Measure:

- Electricity used for heat
- Temperature inside
- Temperature outside


**Btu/hr-F vs dT -- 3 CoHeating Tests  
(dT>12F)**



Electric  
Resistance  
Heating,  
Midnight to  
6 AM Only

*Field data is  
messy!*


## Btu/hr-F vs dT -- 3 CoHeating Tests (dT>12F)



### Improved Heating Systems Sizing for ASHP

|                             | Area      | U-Value     | UA         |
|-----------------------------|-----------|-------------|------------|
| Roof                        | 1,317     | 0.017       | 22         |
| Wall                        | 2,313     | 0.025       | 58         |
| Window                      | 292       | 0.2         | 58         |
| Doors                       | 103       | 0.33        | 34         |
|                             | Perimeter | Btu/ft-F    |            |
| Slab/Basement               | 171       | 0.25        | 43         |
|                             | Volume    | ACH         |            |
| Infiltration**              | 17,125    | <b>0.18</b> | 55         |
| <b>TOTAL UA -- Btu/hr-F</b> |           |             | <b>271</b> |


## Btu/hr-F vs dT -- 3 CoHeating Tests (dT > 12F)



| Improved Heating Systems Sizing for ASHP |           |          |     |
|--|-----------|----------|-----|
|  | Area      | U-Value  | UA  |
| Roof                                     | 1,317     | 0.017    | 22  |
| Wall                                     | 2,313     | 0.025    | 58  |
| Window                                   | 292       | 0.2      | 58  |
| Doors                                    | 103       | 0.33     | 34  |
|  | Perimeter | Btu/ft-F |     |
| Slab/Basement                            | 171       | 0.25     | 43  |
|  | Volume    | ACH      |     |
| Infiltration**                           | 17,125    | 0.18     | 55  |
| TOTAL UA -- Btu/hr-F                     |           |          | 271 |

*Average of  
midnight to 6AM  
coheating test:  
212 Btu/hr-F*

**EFG HP COP -- based on coheating test load  
daily averages**



*Average  
Midnight to  
6AM Heat  
Pump COP*

*Average COP ~1.3*



| <b>EFG Heat Pump COP</b>  |              |                   |                 |
|---------------------------|--------------|-------------------|-----------------|
|                           |              |                   |                 |
| <b>Heat Source</b>        | <b>kWh</b>   | <b>degree-hrs</b> | <b>Btu/hr-F</b> |
|                           |              |                   |                 |
| <b>Resistance Heating</b> | <b>517</b>   | <b>8,306</b>      | <b>212</b>      |
|                           |              |                   |                 |
| <b>Heat Pump</b>          | <b>1,560</b> | <b>32,386</b>     | <b>164</b>      |
|                           |              |                   |                 |
|                           |              | <b>COP</b>        | <b>1.3</b>      |
|                           |              |                   |                 |