
Ground Source Heat Pump System


LN

BIG buffer tank for Makeup Air


- 3,000 gallons
- Allows
 "dumb" heat
 pumps to
 meet varying
 loads
- Reduces peak load on heat pumps
- Reduces
 peak load on
 borehole field



DD Energy Modeling and Optimizing Systems



DD Energy Modeling and Optimizing Systems



The George D. Aiken Center at the University of Vermont




Pre-Renovation Wall Conditions















Detail at floor slab




WALL SECTION AT FLOOR SLAB- NEW CONSTRUCTION

Thermal diagram




Integrated design






George D. Aiken Center - University of Vermont

Daylighting strategy





Wall Section - Solarium





South Elevation View



Proposed Elevation







George D. Aiken Center - University of Vermont

South Elevation


1/08/09




Window head




Total building energy intensity










Integrated Environmental Design & Systems







^{*} Based on energy usage of similar sized existing facility, rough estimate

^{**} Based on computer modeling of building performance and estimates of renewables contribution

^{***} Propane at \$2.50/gallon, pellets at \$250/ton, electricity at Avg \$0.14/kWh

^{****} Purchased non-renewable fuel (propane and grid electricity - PV's estimated to provide 90% of electricity, pellets 95% of thermal)





Energy Conservation







