BUILDINGENERGY BOSTON

Indoor Air Quality: Monitoring Strategies and Results for a Multifamily Passive House Project

Thomas Chase (New Ecology)
Eleni Macrakis (HRI)

Curated by Kurt Roth (Fraunhofer USA)

Northeast Sustainable Energy Association (NESEA) February 28, 2022

NESEA
BuildingEnergy Boston
2022

Indoor Air Quality: Monitoring Strategies for a Multifamily Passive House Project








Who we are.

As a mission-driven nonprofit, New Ecology works nationally to bring the benefits of sustainable development to the community level, with a concerted emphasis on underserved populations.


We seek to make the built environment more efficient, healthy, durable, and resilient.



Who we are.

HRI is a local non-profit affordable housing organization that develops and preserves affordable, high-quality rental housing, with robust resident services for individuals and families throughout our portfolio.

We have a strong focus on responsible and sustainable practices through deliberate energy efficiency and material selection practices to both reduce our carbon footprint and to create healthy and comfortable homes for our residents.



Agenda

- 1. IAQ Monitoring Program Design
- 2. Finch Cambridge IAQ Monitoring Results
- 3. Finch Cambridge IAQ Monitoring Uses
- 4. Future Work
- 5. Q&A

Providing Good IAQ

Source Control

- Materials selection
- Behavior (e.g. pesticide use, cooking)

Ventilation

- 100% outdoor air
- Energy recovery
- Exhaust and supply locations

Filtration

MERV Rating

Monitoring and Corrective Action





Common IAQ Metrics

- ASHRAE Ventilation Rate Guidance (CO₂)
- EPA Radon Guidance
- RESET Air for Residential v1.0

Ventilation and Resultant CO2 Concentrations

| Carbon Dioxide | Outside Air (cfm per person) | CO ₂ Differential (inside/outside) |
|--------------------------|---------------------------------|---|
| 800 ppm suggests about | 20 cfm (or less) | 500 ppm |
| 1,000 ppm suggests about | 15 cfm (or less) | 650 ppm |
| 1,400 ppm suggests about | 10 cfm (or less) | 1,050 ppm |
| 2,400 ppm suggests about | 5 cfm (or less) | 2,050 ppm |

Note: The CO₂ values in this table are approximate, and based on a constant number of sedentary adult occupants, a constant ventilation rate, an outdoor air CO₂ concentration of about 380 ppm, and good mixing of the indoor air.

 ${\rm *current\,atmospheric\,CO_2\,concentration} > 410 {\rm ppm:\,https://www.climate.gov/news-features/understanding-climate/climate-change-atmospheric-carbon-dioxide}$





Metrics: RESET Standard

Monitors

Buildings





| PM2.5 Particulate Matter | TVOC Total Volatile Organic Compounds | CO ₂ Carbon Dioxide | Temp Temperature | RH Relative Humidity | CO** |
|--------------------------------------|---|-----------------------------------|---|-------------------------|--|
| Acceptable < 35 µg/m ³ | Acceptable < 500 µg/m³ | Acceptable < 1000 ppm | Monitored | Monitored | Acceptable < 9 ppm |
| High Performance < 12 µg/m³ | High Performance < 400 μg/m ³ | High Performance < 600 ppm | Although there are no requirements for temperature and humidity under RESET™ Air, both must be monitored given their impact on sensor readings for PM2.5 and TVOC. | | CO monitors are only required in spaces with combustion. |





IAQ Monitoring Equipment























IAQ Case Study









Finch Cambridge Passive House

Green Building Certification Requirements

PHIUS+ 2015

ASHRAE 62.2-2010
Outside air to bedrooms

EPA Indoor airPLUS

ENERGY STAR

Low-CH₂O plywood and composite

wood

Low-VOC paints, finishes, carpet,

carpet adhesives

MERV 8 filtration for forced air space

conditioning

ENERGY STAR

ASHRAE 62.2-2010 or 2013

(residential)

ASHRAE 62.1-2010 or 2013

(common space)

<50% more than 62.1-2013

Enterprise Green Communities 2015

ENERGY STAR

Radon mitigation

Low-VOC paints, coatings, primers,

adhesives, sealants







Finch Cambridge Passive House

Ventilation Systems

- Design
- Commissioning









| Space Type | Radon | CO2 | TVOC | Temp | RH | Pressure |
|--|----------|----------|----------|----------|----------|----------|
| Lobby, Conference Room, Community Room, Lounge | ✓ | ~ | ✓ | ~ | ✓ | ~ |
| Apartments (Sample of 20) | ✓ | ✓ | ~ | ✓ | ✓ | ✓ |
| Apartments (All 98) | | | ✓ | ✓ | ✓ | ~ |









Indoor Air Quality

Radon

Airthings Wave Plus Air Quality

Monitor

Lobby, Conference CO2 Room, Community TVOC Room, Lounge, 20 Temperature Apartment Units

Humidity Pressure Light







pCi/L 24h avg RADON

ಕೆ 112 VOC

A 31% HUMIDITY € 69° TEMP

₫ 1032 PRESSURE









Airthings Wave Mini Air Quality Monitor

78 Apartment Units Indoor Air Quality TVOC Temperature Humidity Pressure Light

























Hub



Ground Floor Offices 3rd Floor Tel/Data Airthings Room Communication 4th Floor Storage Room (STO 09) 5th Floor Tel-Data Room Community Room









Sensor sampling interval: 5 minutes

Sensor Resolution:

Temperature ∓ 0.1°C / ∓ 0.1°F

Humidity ∓1%

Pressure ∓0.15hPa

Settling time:

TVOC ~ 7 days

CO₂ ~ 7 days

CO, details:

NDIR Sensor (Non-Dispersive Infra-Red):

Measurement range 400-5000 ppm

Non condensing 0 - 85%RH

Optimum Accuracy ± 30 ppm $\pm 3\%$ within 15 - 35°C / 60 - 95°F

and 0 - 80%RH

Radon sampling: Passive diffusion chamber

Detection method: Alpha spectrometry

Measurement range: 0 - 500 pCi/L / 0 - 20,000 Bq/m³

Accuracy/precision at 5.4 pCi/L / 200 Bq/m³:

After 7 days ~ 10 %

After 2 months ~ 5 %











Property IAQ Policies



- Smoke-Free Policy
- Green Guide
- IAQ Monitoring
- Integrated Pest Management
- Robust Resident Services
















IAQ Monitoring Findings

Temperature




| Space | Min. Temp. | Max. Temp. | Avg. Min. Temp. | Avg. Max. Temp. | Avg. Temp. |
|-------------------|---------------|---------------|-----------------------|-----------------------|---------------|
| Apartment Average | 32.0 °F | 94.0 °F | 69.1 °F | 76.2 °F | 74.7 °F |
| Lobby | n/a | n/a | 53.8 °F | 80.4 °F | 71.2 °F |
| Conference Room | n/a | n/a | 54.5 °F | 81.4 °F | 73.1 °F |
| Community Room | n/a | n/a | 60.4 °F | 89.5 °F | 74.7 °F |
| Lounge | n/a | n/a | 56.5 °F | 90.4 °F | 72.4 °F |







IAQ: Temperature










IAQ: Temperature










IAQ Monitoring Findings

Relative Humidity



| Space | Min. RH | Max. RH | Avg. RH |
|-------------------|---------|---------|---------|
| Apartment Average | 27.5% | 57.1% | 44.0% |
| Lobby | 5.0% | 74.5% | 38.9% |
| Conference Room | 6.5% | 78.5% | 39.3% |
| Community Room | 5.5% | 84.0% | 40.2% |
| Lounge | 7.0% | 81.5% | 43.2% |








IAQ: Relative Humidity

Relative Humidity at Finch










IAQ Monitoring Findings Total VOCs




| Space | Min. TVOC | Max. TVOC | Avg. TVOC |
|-------------------|--------------|--------------|--------------|
| Apartment Average | 74 μg/m³ | 442 μg/m³ | 202 μg/m³ |
| Lobby | 0 μg/m³ | 8,295 μg/m³ | 1,306 μg/m³ |
| Conference Room | 0 μg/m³ | 1,311 μg/m³ | 155 μg/m³ |
| Community Room | 0 μg/m³ | 8,277 μg/m³ | 197 μg/m³ |
| Lounge | 0 μg/m³ | 8,287 μg/m³ | 231 μg/m³ |







IAQ: Total VOCs










IAQ: Total VOCs

Average Community Room Total VCOs










IAQ Monitoring Findings

Carbon Dioxide (CO₂)



| Space | Min. CO ₂ | Max. CO ₂ | Avg. CO ₂ |
|---------------------------|-------------------------|-------------------------|-------------------------|
| Apartment Average (ERV 1) | 433 ppm | 2,596 ppm | 783 ppm |
| Apartment Average (ERV 2) | 428 ppm | 2,082 ppm | 691 ppm |
| Lobby | 385 ppm | 954 ppm | 486 ppm |
| Conference Room | 382 ppm | 2,114 ppm | 482 ppm |
| Community Room | 368 ppm | 1,114 ppm | 474 ppm |
| Lounge | 360 ppm | 1,475 ppm | 485 ppm |








IAQ: CO₂

$\ \, \text{Average Community Room CO}_2$










IAQ: CO₂











IAQ Monitoring Findings

Radon

Radon

EPA Action level = 4 pCi/L

| Space | Min. Radon | Max. Radon | Avg. Radon |
|-------------------|------------|------------|---------------|
| Apartment Average | 0.09 pCi/L | 1.29 pCi/L | 0.23 pCi/L |
| Lobby | 0.00 pCi/L | 2.35 pCi/L | 0.53 pCi/L |
| Conference Room | 0.00 pCi/L | 3.32 pCi/L | 0.71 pCi/L |
| Community Room | 0.00 pCi/L | 2.19 pCi/L | 0.28 pCi/L |
| Lounge | 0.00 pCi/L | 1.97 pCi/L | 0.22 pCi/L |







IAQ Monitoring Uses by Property Management

Resident Experience

Thermal Comfort


- Limited Thermostats
- Resident Requests for higher heat and lower A/C

Odors in Common Areas

 Troubleshooting malfunctioning ERVs and confirming repairs

Systems Management

IAQ monitors help confirm issues with the ERV systems









IAQ Monitoring Uses by Property Management

Balancing Real Time Data with Resident Privacy

- Provide a healthy comfortable environment for our residents
- Avoid policing resident behavior unless it affects the health and safety of other residents and/or staff
- Examples of disastrous IAQ situations due to misguided resident behavior that we try and avoid
 - Ex: Resident humidification causing dramatic mold growth
 - Ex: Resident use of space heaters, risk of fire









Future Work

Deployment

- All units, selected units, portable monitors
- Common spaces
- Ventilation air flow monitors
- Wireless hub connectivity in masonry and concrete buildings

PM2.5 monitoring

Too much data, not enough information

HUD-NCHH PM2.5 monitoring in passive house vs. conventional multifamily






Future Work

Too much data, not enough information.







Thank You!

Tom Chase

Senior Project Manager chase@newecology.org 617-557-1700 x7061

Eleni Macrakis

Project Manager emacrakis@homeownersrehab.org 617-868-4858 x209



