BUILDINGENERGY BOSTON

Size and Selection Matter: Using New Data and Tools to Design Effective Heat Pump Systems

Dave Lis (NEEP) Mike Ostiguy (Abode Energy Management) Christopher Haringa (Abode Energy Management)

Curated by Kurt Roth

Northeast Sustainable Energy Association (NESEA) March 29, 2023



Size and Selection Matter: Using New Data and Tools to Design Effective Heat Pump Systems

- Dave Lis, Director, Technology and Market Solutions
- Northeast Energy Efficiency Partnerships (NEEP)
- BuildingEnergy Boston
- March 29, 2023



Northeast Energy Efficiency Partnerships

Mission

We seek to accelerate regional collaboration to promote advanced energy efficiency and related solutions in homes, buildings, industry, and communities.

Approach

Drive market transformation regionally by fostering collaboration and innovation, developing tools, and disseminating knowledge



Key challenges to sizing/selecting ASHPs in cold climates

- "Sizing" across wide range of operating conditions and heating/cooling loads
- Availability of useful performance data


Load Matching

- Heating design load can be 3X+ cooling design load in cold climates
- Heat pumps have unique capacity "maps"
- Requires system "sizing" across wide range of operating conditions, heating/cooling loads
- Can't be too small for heating
- Can't be too big for moderate heating/cooling




Availability of useful heat pump performance data

- Usefulness of "Rated" performance data
 - Fixed speed testing
 - Range of temperature points
- Accessing extended performance data




NEEP's Cold-Climate ASHP Product List




What do I do with this?

Heating / Cooling	Outdoor Dry Bulb	Indoor Dry Bulb	Unit	Min	Rated	Max
Cooling	95°F	80°F	Btu/h	3,400	12,000	13,300
			kW	0.14	0.96	1.27
			COP	7.12	3.66	3.07
Cooling	82°F	80°F	Btu/h	3,600	-	14,400
			kW	0.12	-	1.09
			COP	8.79	-	3.87
Heating	47°F	70°F	Btu/h	2,800	14,500	19,100
			kW	0.14	1.03	1.67
			COP	5.86	4.13	3.35
Heating	17°F	70°F	Btu/h	3,200	8,800	12,700
			kW	0.36	0.88	1.39
			COP	2.61	2.93	2.68
Heating	5°F	70°F	Btu/h	2,700	-	10,700
			kW	0.33	-	1.28
			COP	2.4	-	2.45
	ł	Heating/Coo	oling Ca	apacity Gra	ph	





New Sizing tool functionality



Product Sizing For Heating

Field Information ()

Field Information ()

Balance Point (°F)	5
Minimum Capacity Threshold (°F)	44
Maximum Capacity at Design Temp (Btu/hr)	25,220
Percent Design Load Served	98.9%
Annual Heating Load (MMBtu)	61.7
Percent Annual Heating Load Served	97.9%

1.3
54
0.9%
83.9%
12.6%

Demo time!

- Assessing product performance match with application
 - Visualization
 - Calculations
- Impact of sizing choices within same product line
- Impact of potential load reductions
- Assessing need for supplemental/back-up heat
- Down selecting complete list

Limitations of data and tool

- Extended performance data- Manufacturer reported
 - No Industry standard procedure to determine variable performance
 - Data quality
- Unable to "build up" a solution with multiple outdoor units
- Does not include cooling load line
- Does not calculate the expected energy consumption of different options

Tracking tool users and uses

- Contractors:
 - New insights into selection decisions
 - Differentiator with customers
- Distributors:
 - Confirm they are stocking well for local climates
 - Use at the counter for engaging contractors
 - Swap outs due to supply chain issues
- Programs/Service Providers
 - Contractor training tool
 - Contractors QC
 - 1:1 coaching
- Homeowners:
 - Consumer empowerment
 - Sanity check on quotes

Abode Energy Management




% FOR THE PLANET

ABODE'S WORK IN THE EFFORT TO SCALE HEAT PUMP ADOPTION

		Heat Pump Related Services					
Client Examples	Abode's Role	Consultations	Quote Reviews	Contractor Networks	Trainings	QA	
mass save Savings through energy efficiency	Mass Save Home Performance Contractor Lead Vendor						
Proud sponsor of energize	Providing Heat Pump Support for Energize CT Customers	~	~	~	~		
MASSACHUSETTS CLEAN ENERGY CENTER	Leading the Decarbonization Pathways and Triple Decker Retrofit Pilots	~	<			~	
9 MLP Utilities and 7 Communities in MA	Providing Heat Pump Support for MLP Customers	~	~	~	~	~	

HOMEOWNERS ARE CONFUSED WHEN THEY GET QUOTES



NEEP DATA HELPS US ESTIMATE HOME SPECIFIC PERFORMANCE DUOTE OVERVIEW 55 VIIGIDIA CONCOL, MA

Inputs

- Home characteristics
- Fuel usage data
- Contractor quotes
- NEEP data

Analysis

- Estimate heating load
- Bin temperature data analysis
- Apply cycling, defrost, and multi-zone adjustments

OUOTE OVERVIEW 55 Virginia Rd. Concord, MA The following charts provide insights into how the quoted systems compare. Actual operating cost and CO2 impact may vary based on: Equipment selection, design, and installation Customer behavior operating installed equipment Use of existing heating and cooling equipment and auxiliary heat

Operating Costs Change


Bars that extend to the right of "0%" reflect greater savings compared to existing HVAC systems. It is important to think of your operating costs on an annual basis and compare to current utility rates versus what you may have paid in the past.

Impact on Heating and Cooling Cost⁴ Ouote A Ouote B Ouote C 60% 0% -60% Higher cost

Environmental Benefits Bars that extend to the right of "0%" reflect a greater environmental benefit compared to existing HVAC systems. As your electric utility continues to source more clean energy for generation, the environmental benefits of your system will only improve.

-60%

lower CO2



Home specific operating cost and CO2 comparison

Performance

Systems that are shown furthest to the right in each chart are estimated to operate more efficiently with lower operating costs.



Sizing

The green shaded area represents the likely acceptable sizing range for your home's healing needs based on the usage data provided by the customer. Systems within this range should perform better and provide superior comfort compared to systems that may be under or oversized.

System Size³ Ouote A Ouote B Ouote C 20 30 40 50 60 70 80 90 100 x1000 BTUs

Cycling Transition Temperature Systems shown further to the right are estimated to cycle on

and off less frequently as thermostat calls for heat, reducing the risk of comfort and performance issues.



Estimated cycling comparison

Estimated seasonal performance

Estimated "optimal" sizing range

based on location

Footnotes

1. Cost savings and CO2 emissions estimates are based on customer-provided fuel usage (when available), regional temperature data, and basic information about the home, and are not an exact representation of how the home performs.

More cycling

2. Seasonal performance of equipment is estimated based on manufacture-provided data, statistical temperature history, and estimate of cycling and defrost losses.
3. Estimate heating lossia are based on castomer provided the usage perform exalible, regional temperature data, and basic information about the home, and are not an exact representation of how the home performs. The sizing chart is intended for directional guidance and should not be solely relied upon for equipment selection or sizing of equipment.

Report generated by: Abode HVAC Specialist 6/2/2022

Less cycling

WHY THE DETAILS MATTER

Temperature	COP and Capacity Data	Story 1 (HSPF2)	Story 2 (Quote Review)
	Min		 Image: A start of the start of
47 Degrees	Rated	 Image: A second s	 Image: A start of the start of
	Max		 Image: A start of the start of
	Min		 Image: A start of the start of
17 Degrees	Rated	 Image: A second s	
	Max		
	Min		
5 Degrees	Rated	Optional in 2023	
	Max		 Image: A start of the start of
	Min		 Image: A start of the start of
LCT	Rated		 Image: A start of the start of
	Max		
Temperature data	à	Mid Atlantic Region IV (Not most of New England)	Local
Defrost penalty		 Image: A second s	 Image: A start of the start of
Cycling penalty		Default	More Realistic
Multi-zone penalt	У		
Aux. electric pena	alty	 Image: A start of the start of	
Fixed sizing assu	mption	Locked mode	Assumes modulation
		1	1

Performance data can tell different stories

Story 1

- Where we normally look to compare performance
- What qualifying product lists and rebates are typically based on

Story 2

- Based on more complete manufacturer provided data
- A more detailed model of how equipment should perform under various loads
- Others using similar bin analysis approach

WHY THE DETAILS MATTER

What we used to focus on

High HSPF & SEER

A good Manual J and avoiding oversizing

High turndown ratio

High capacity maintenance @5

Avoid large multi-zones

Encourage single-zones

Avoid branch boxes

Split systems by floor or "like conditions"

Encourage ducted systems for closed off spaces

AS WE LEARN MORE, SOME BEST PRACTICES MIGHT NEED TO SHIFT

What we used to focus on

High HSPF & SEER

A good Manual J and avoiding oversizing

High turndown ratio

High capacity maintenance @5

Avoid large multi-zones

Encourage single-zones

Avoid branch boxes

Split systems by floor or "like conditions"

Encourage ducted systems for closed off spaces

How that's changing

Replace with Quote Review or deeper dive into NEEP data

Include Min COPs and Min capacities as key drivers

Replace with Min capacity at 47, 17, and 5

Include Max capacity below 5 and new messaging

Weigh the drop in COP moving to some smaller equipment

Always confirm COPs, some single-zones seem to "test well"

Jury is still out on some newer equipment that looks appealing

No change

No change

SAME PRODUCT LINE, DIFFERENT SIZE, DIFFERENT PERFORMANCE

Example 1: Commonly sold product line 1

System Size	HSPF Equivalent COPH	COPH Estimated with tool	% of HSPF Equivalent
24 kbtu	3.1	1.9	61%
30 kbtu	3.2	→ 1.9	59%
36 kbtu	3.4	→ 2.4	71%
42 kbtu	3.4	2.7	80%

Example 2: Commonly sold product line 2

System Size	HSPF Equivalent COPH	COPH Estimated with tool	% of HSPF Equivalent
30 kbtu	3.2	→ 2.2	68%
36 kbtu	3.3	2.9	88%
42 kbtu	3.2	→ 3.0	93%
48 kbtu	3.4	2.8	83%

– – – HSPF

80

100

Rated Cooling Max Cooling ---- SEER

6.DD

5.00

3.00

1.00


-20

20

40

Temperature (F)

60



MIN COPS RELATIVE TO OTHER RATINGS COULD BE IMPACTFUL

High	Min COPs	s (~3.7)
(increa	ises SCOP)	

Average Min COPs (~2.5) (minor decrease in SCOP)


Inverted Max and Min COPs (~1.9) *(major decrease in SCOP)*


Heating / Cooling	Outdoor Dry Bulb	Indoor Dry Bulb	Unit	Min	Rated	Max
Heating	47°F	70°F	Btu/h	6,600	36,600	54,500
		kW	0.26	2.52	5.45	
			COP	7.44	4.26	2.93
Heating 17°F	17°F	70°F	Btu/h	5,080	22,400	41,960
		kW	0.26	2.36	5.4	
			COP	5.73	2.78	2.28
Heating 5°F	5°F	70°F	Btu/h	4,420	-	36,600
			kW	0.25	-	5.36
			COP	5.18	-	2


Heating / Cooling	Outdoor Dry Bulb	Indoor Dry Bulb	Unit	Min	Rated	Max
Heating	47°F	70°F	Btu/h	10,248	28,600	34,200
			kW	1.3	2.33	3.26
		COP	2.31	3.6	3.07	
Heating 17°F	17°F	17°F 70°F	Btu/h	7,511	18,900	31,600
		kW	1.08	1.98	3.69	
			COP	2.04	2.8	2.51
Heating	5°F	70°F	Btu/h	6,262	-	28,600
			kW	0.97	-	3.88
			COP	1.89	-	2.16

Heating Load (MBtu/h)
Max HP Capacity (MBtu/h)

Min HP Capacity (MBtu/h)
 Delivered Capacity (MBtu/h)







VARIABILITY IN MIN CAPACITY ADDS SIZING COMPLEXITY Heating / Outdoor Indoor Dry

Min capacity **slopes down** (*More forgiving to oversizing*)


Min capacity is **flat** (*It depends*)

Min capacity **slopes up** (*Less forgiving to oversizing*)

Handing (0.44	Indexe Deve							
Heating / Cooling	Outdoor Dry Bulb	Indoor Dry Bulb	Unit	Min	Rated	Max			
Heating	47°F	70°F	Btu/h	27,000	54,000	54,000			
			kW	1.4	4.22	4.22			
			COP	5.65	3.75	3.75			
Heating	17°F 70°F Btu/h 1	11,620	38,000	54,000					
		701				kW	0.92	4.13	6.87
			COP	3.7	2.7	2.3			
Heating	5°F	70°F	Btu/h	8,020	-	54,000			
		kW	kW	0.74	-	7.91			
			COP	3.18	-	2			


Heating / Cooling	Outdoor Dry Bulb	Indoor Dry Bulb	Unit	Min	Rated	Max
Heating	47°F	70°F	Btu/ł	16,000	37,500	43,000
			kW	0.81	3.35	4.1
		COP	5.79	3.28	3.07	
Heating	Heating 17°F	70°F	Btu/ł	24,000	23,800	39,400
			kW	2.03	2.65	5.91
			COP	3.46	2.63	1.95
Heating 5°F	70°F	Btu/ł	24,000	-	37,500	
			kW	2.43	-	6.27
			COP	2.89	-	1.75

COLD SNAP IN FEB HIGHLIGHTS WHY THE DETAILS MATTER



Did you switch to a backup heat source?


Did the heat pumps maintain normal temperatures?



Based on survey responses from 200 "whole home" heat pump owners in eastern Massachusetts

"Whole home" defined as equipment sized to serve at least 90% of the home and 100% of the heating load

ABILITY TO OPERATE AT LOW TEMPS APPEARS LESS MEANINGFUL THAN THE CAPACITY RATING



This doesn't change how you size equipment, but might change what you select, and how you message backup heat

Other Interesting Survey Results

- Ducted vs. ductless didn't seem to have a meaningful impact on temperature drop
- Of the group where the temperature dropped, 51% said they were expecting the HPs to fall behind, 22% were not, and 27% didn't know what to expect
- Of the group that switch to a backup, 88% switched to a fossil fuel system
 - Of those, 86% maintained temperature

SUMMARY

- HSPF and SEER have limited value in New England
- Min, Max, and Rated values are the best window we have into heat pump performance under various loads
- If accurate, there's more variability in performance than expected
- As we learn more, some best practices might need to shift
- Initial areas of focus (for now)
 - O Check ratings when moving up or down a size in a product line
 - Look for high Min COPs and avoid inverted Min COPs
 - Get the full Min Capacity picture at all 3 temperatures
 - O Don't change how you size but consider capacity maintenance below 5 degrees



Related Activities

- Version 2.0 of sizing tools in the works
 - Multi-product buildup
 - Weather station selection improvement
 - Multi-unit comparison view
 - Cooling capacity, latent load cross check
- NEEP Rating Representativeness project
- Standardizing expanded performance data
- Updates to ACCA Guides
- Updating NEEP Sizing/Selection Best Practice Guides and Videos



Group Discussion

- What improvement opportunities resonate with stakeholders in the audience?
- Are there other future directions we should be considering?



Links

- Cold Climate Air-source Heat pump Product List (including sizing tools); <u>https://ashp.neep.org/</u>
- User Guide: Cold Climate Heat Pump Sizing Support Tools; <u>https://ashp-production.s3.amazonaws.com/NEEP_ccASHP+Heating+Visualization+User</u> +Guide v2.2 TRC 04.01.22.pdf
- Cold Climate Air-source Heat pump Specification; https://neep.org/heating-electrification/ccashp-specification-product-list
- Installer Guides/Videos; https://neep.org/high-performance-air-source-heat-pumps/air-source-heat-pump-installer-and-consumer-resources
- Heat Pump Initiative; <u>https://neep.org/smart-efficient-low-carbon-building-energy-solutions/air-source-heat-pumps</u>

Multi-zone indoor head oversizing

- What happens when only one zone is calling for heat?
- Avoid situations where the minimum steady-state capacity of the outdoor unit (at 47F) is higher than the smallest indoor unit's heating capacity.
- Can impact humidity control as well if short cycling during the cooling season

