



AC Energy & Cost Savings



(Type comments here to appear on printout; maximum 1 row of 90 characters.)

Station Identification	
Cell ID:	0266375
State:	Delaware
Latitude:	39.1 ° N
Longitude:	75.4 ° W
PV System Specifications	
DC Rating:	12.0 kW
DC to AC Derate Factor:	0.758
AC Rating:	9.07 kW
Array Type:	Fixed Tilt
Array Tilt:	33.7 °
Array Azimuth:	210.0 °
Energy Specifications	
Cost of Electricity:	9.1 ¢/kWh

Results			
Month	Solar Radiation (kWh/m ² /day)	AC Energy (kWh)	Energy Value (\$)
1	3.09	877	79.79
2	3.69	942	85.70
3	4.98	1366	124.28
4	5.17	1327	120.73
5	5.68	1462	133.01
6	5.86	1407	128.01
7	5.64	1391	126.55
8	5.31	1308	119.00
9	5.12	1239	112.72
10	4.45	1163	105.81
11	3.24	851	77.42
12	2.93	801	72.87
Year	4.60	14133	1285.82

Output Results as Text

[Saving Text from a Browser](#)

Run [PVWATTS v.2](#) for another location

Run [PVWATTS v.1](#)

Please send questions and comments to [Webmaster](#)
[Disclaimer and copyright notice.](#)

