Home Energy Rating Certificate HERS

Single-family detached

Conditioned basement

Property
Paul & Julia Torcellini
76 Weeks Road
Eastford, CT 06242

HERS Index: 2

General Information

Conditioned Area

Bedrooms

Heating:

Cooling:

Ceiling Flat

Sealed Attic

Vaulted Ceiling

Above Grade Walls

Foundation Walls

Mechanical Systems Features Heating:

Conditioned Volume

Duct Leakage to Outside

Programmable Thermostat

Building Shell Features

Ventilation System

3597 sq. ft.

3

NA

R-50.0

R-51.6

R-23 0

NA

NA

35222 cubic ft.

eks Road	
rd, CT 06242	

Rating Type: Confirmed Rating Date: 2015/12/30 Registry ID: 714436569

House Type

Foundation

Slab

Method

R-66.5

Exposed Floor

Window Type

Infiltration Rate

Air-source heat pump, Electric, 11.5 HSPF.

Air-source heat pump, Electric, 26.1 SEER.

Air-source heat pump, Electric, 3.7 COP.

Balanced: HRV, 74 cfm, 54.0 watts.

Heat=Yes; Cool=Yes

Certified Energy Rater:

Rating Number:

Karla Butterfield

Estimated Annual Energy Cost				
Use	MMBtu	Cost	Percent	
Heating	17.4	\$645	806%	
Cooling	4.0	\$75	93 %	
Hot Water	4.0	\$225	282%	
Lights/Appliances	25.8	\$1359	1 699 %	
Photovoltaics	-42.2	\$-2223	-2780%	
Service Charges		\$0	0%	
Total	9.0	\$80	100%	

Criteria

This home meets or exceeds the minimum criteria for the following: **EPA ENERGY STAR Version 2 Home EPA ENERGY STAR Version 2.5 Home** EPA ENERGY STAR Version 3 Home **EPA ENERGY STAR Version 3.1 Home** 2006 International Energy Conservation Code 2009 International Energy Conservation Code 2012 International Energy Conservation Code

	11 2010	Method	
Lights and Appliance	Features		
Percent Interior Lighting	100.00	Range/Oven Fuel	Electric
Percent Garage Lighting	100.00	Clothes Dryer Fuel	Electric
Refrigerator (kWh/yr)	383	Clothes Dryer EF	3.01
Dishwasher Energy Factor	0.46	Ceiling Fan (cfm/Watt)	0.00

Steven Winter Design 61 Washington Street Norwalk, CT 06854 203.857.0200 Fax #

REM/Rate - Residential Energy Analysis and Rating Software v14.6.1

This information does not constitute any warranty of energy cost or savings. © 1985-2015 Noresco, Boulder, Colorado. The Home Energy Rating Standard Disclosure for this home is available from the rating provider.

R-10.0 Edge, R-0.0 Under

Htg: 440 Clg: 440 CFM50

Blower door test

U-Value: 0.300, SHGC: 0.260